



TEXAS DEPARTMENT OF LICENSING & REGULATION

Regulatory Program Management Division • PO Box 12157 • Austin, Texas 78711 • (512) 463-6599

www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX235497	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input type="checkbox"/> INTERNAL <input checked="" type="checkbox"/> NON-CERTIFICATE	<input checked="" type="checkbox"/> EXTERNAL <input type="checkbox"/>	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> JUNKED	<input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> DISPOSITION UNKNOWN	<input type="checkbox"/> EXEMPT <input type="checkbox"/>	<input type="checkbox"/> NEW <input checked="" type="checkbox"/> 2ND HAND
-------------------	---	--	--	---	--	---	--

IDENTIFIED BY: * <input checked="" type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME * United Airlines, Inc. (Chelsea Kitchen)	NAME Chelsea Kitchen c/o United Airlines	NAME Chelsea Kitchen c/o United Airlines
--	--	--

(Address 1) * 4507 Wright Rd	(Address 1) PO Box 60307	(Address 1) PO Box 60307
--	------------------------------------	------------------------------------

(City, State, Zip) * Houston, TX 77032-5219	(City, State, Zip) Houston, TX 77205	(City, State, Zip) Houston, TX 77205
---	--	--

LOCATION PHONE:	OWNER PHONE:	CONTACT NAME: Chelsea Kitchen c/o United Airline
-----------------	--------------	---

OBJECT LOCATION: * BOILER ROOM	BUSINESS EMAIL: DEBLEDWARDS@UNITED.COM	CONTACT PHONE:
Nature of Business: Food	BUSINESS EMAIL: DEBLEDWARDS@UNITED.COM	

MANUFACTURER * Superior Boiler Works	NAT'L BOARD # 007389	SERIAL NUMBER 7389	MFGR MODEL # 5-5-304
--	--------------------------------	------------------------------	--------------------------------

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE CLASS *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
150	1975	12	Fire Tube	Power Boiler	Steam Greater than 15 PSI	304		2070-LB/HR	2070-LB/HR	S

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST * 150	TOTAL CAP. * 10818	# OF SAFETIES 1	<input type="checkbox"/> PROBE TYPE	<input checked="" type="checkbox"/> FLOAT & CHAMBER	Natural Gas/Fuel Oil	BTU/HR OUTPUT
LOWEST * 150	<input type="checkbox"/> BTU/HR	<input checked="" type="checkbox"/> #/HR	<input type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____		
EXPANSION TANK ASME * <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A			EXPANSION TANK MAWP	EXTERNAL PIPE ASME <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A		

EXTENSION INSPECTION? <input type="checkbox"/> YES <input type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
--	---

Comments: Boiler passes external non-certificate inspection. Boiler running steady at 90 PSIG. Flame swirl appears normal and no refractory issues observed near burner throat.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.

Paul Torrance
SIGNATURE OF INSPECTOR

Paul Torrance

1940

TX COMMISSION #

OneCIS Insurance Company

INSPECTION ORG.

Syed Hasan - Maintenance Manager

SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION *

01/29/2021

DATE (MM/DD/YY) *

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? * YES NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)