

## CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

### IMPORTANT ACCIDENT INFORMATION:

**In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and/or via email at**

[boilers@license.state.tx.us](mailto:boilers@license.state.tx.us)

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

**Web site: [www.license.state.tx.us](http://www.license.state.tx.us)**

#### FOR CERTIFICATE QUESTIONS

**Email:** [CSBoiler@license.state.tx.us](mailto:CSBoiler@license.state.tx.us)

(800) 722-7843 or (512) 539-5707

#### FOR TECHNICAL QUESTIONS

**Email:** [boilers@license.state.tx.us](mailto:boilers@license.state.tx.us)

(512) 539-5717

VICTORIA POWER STATION  
1205 SOUTH BOTTOM STREET  
VICTORIA TX 77901

# BOILER CERTIFICATE OF OPERATION

Inspection Type:  
**EXTERNAL**

Date of Inspection:  
**SEPTEMBER 02 2010**

Certificate Expiration Date:  
**OCTOBER 01 2011**

Location:  
VICTORIA POWER STATION  
1205 SOUTH BOTTOM STREET  
VICTORIA TX 77901

Texas Boiler Number:

**239271**

Manufacturer:  
**THERMAL ENGR**

National Board Number:  
**000584**

Manufacturer's Serial Number:  
**17405-1C**

Pressure Allowed: **125 psig**

S/SR Valve Setpoint: **125 psig**

**The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.**



William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201101140021**