



TEXAS DEPARTMENT OF LICENSING AND REGULATION

Licensing Division
 (512) 463-6599 - (800) 803-9202
 Fax (512) 475-2871 csboiler@tdlr.texas.gov

Technical
 (512) 539-5716
 boilers@tdlr.texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# *	* <input type="checkbox"/> 1ST INSPECTION	<input checked="" type="checkbox"/> INTERNAL	<input type="checkbox"/> EXTERNAL	STATUS: *	<input checked="" type="checkbox"/> ACTIVE	<input type="checkbox"/> DISCONNECTED IN PLACE	<input type="checkbox"/> EXEMPT	<input checked="" type="checkbox"/> NEW
TX260053	<input checked="" type="checkbox"/> SUBSEQUENT	<input type="checkbox"/> NON-CERTIFICATE			<input type="checkbox"/> JUNKED	<input type="checkbox"/> DISPOSITION UNKNOWN		<input type="checkbox"/> 2ND HAND

IDENTIFIED BY: * DECAL STAMP TAG VARIANCE: * YES NO TEXAS SPECIAL: * YES NO

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME *	NAME	NAME
United Laboratories Manufacturing LLC	UNITED ONE INTERNATIONAL LABS	United Laboratories Manufacturing LLC

(Address 1) *	(Address 1)	(Address 1)
1541 Champion Drive	1541 Champion Dr	1541 Champion Dr

(City, State, Zip) *	(City, State, Zip)	(City, State, Zip)
Carrollton, TX 75006-6814	Carrollton, TX 75006-6814	Carrollton, TX 75006-6814

LOCATION PHONE: 972-490-3300	OWNER PHONE: (972)490-3300	CONTACT NAME: Tyson Thurman
-------------------------------------	-----------------------------------	------------------------------------

OBJECT LOCATION: *	OWNER EMAIL: jjgibson@united1labs.com	CONTACT PHONE: 469 865-3360
--------------------	--	------------------------------------

PRODUCTION	Nature of Business: Manufacture	CONTACT EMAIL: tthurman@united1Labs.com
-------------------	--	--

MANUFACTURER *	NAT'L BOARD #	SERIAL NUMBER	MFGR MODEL #
PACIFIC STEAM	12769	12769	PSE36

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
100	2013	12	Electric	Power	14		122-LB/HR	122-LB/HR	M

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST *	TOTAL CAP. *	# OF SAFETIES	<input type="checkbox"/> PROBE TYPE	<input checked="" type="checkbox"/> FLOAT & CHAMBER	Electricity	126000
100	644	1	<input type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____		BTU/HR OUTPUT
LOWEST *			<input type="checkbox"/> BTU/HR <input checked="" type="checkbox"/> #/HR	MAWP: 150		
100						

EXPANSION TANK ASME * YES NO N/A EXPANSION TANK MAWP EXTERNAL PIPE ASME YES NO N/A

EXTENSION INSPECTION? YES NO EXTENSION APPROVAL DATE (IF APPLICABLE)

Comments: Internal surfaces had minor scale accumulation present. No cracking or pitting was observed. The element was clean with no scale bridging present or sagging observed. The LWCO float chamber was clean and the float assembly was intact. The water column piping was clear with no restrictions observed.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.

Matthew Sobotka

 SIGNATURE OF INSPECTOR
 Matthew Sobotka

2007

 TX COMMISSION #

0006

 INSPECTION ORG.

Tyson Thurman, Maintenance, 469-865-3360

 SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION *

11/24/2017

 DATE (MM/DD/YY) *

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? * YES NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)