

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and /or via email at boilers@license.state.tx.us.

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.tdlr.texas.gov

FOR CERTIFICATE QUESTIONS

Email: csboiler@tdlr.texas.gov
(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@license.state.tx.us
(512) 539-5717

MCCASH ENTERPRISES INC
ATTN SCOTT MCCASH
PO BOX 311553
NEW BRAUNFELS TX 781311553

BOILER CERTIFICATE OF OPERATION

Inspection Type:
Internal

Date of Inspection:
August 15, 2014

Certificate Expiration
August 15, 2015

Texas Boiler Number:
TX235866

Manufacturer:
FULTON BOILER

National Board Number:
104786

Manufacturer's Serial Number:
104786

Pressure Allowed: **150** psig

S/SR Valve Setpoint: **150** psig

LOCATION:

MCCASH ENTERPRISES INC
692 S WALNUT AVE
NEW BRAUNFELS, TX 78130-5723

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.


William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201409300076**