



# TEXAS DEPARTMENT OF LICENSING AND REGULATION

Licensing Division  
(512) 463-6599 - (800) 803-9202  
Fax (512) 475-2871 csboiler@tdlr.texas.gov

Technical  
(512) 539-5716  
boilers@tdlr.texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

## Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX078591	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input type="checkbox"/> INTERNAL <input type="checkbox"/> NON-CERTIFICATE	<input checked="" type="checkbox"/> EXTERNAL	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> JUNKED	<input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> DISPOSITION UNKNOWN	<input type="checkbox"/> EXEMPT <input type="checkbox"/> 2ND HAND	<input type="checkbox"/> NEW
-------------------	---	---	--	---	--	--	------------------------------

IDENTIFIED BY: * <input type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input checked="" type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME *	NAME	NAME
--------	------	------

Sycamore Elementary School - Crowley CISD	Crowley CISD	Crowley CISD
---	--------------	--------------

(Address 1) *	(Address 1)	(Address 1)
---------------	-------------	-------------

1601 Country Manor Rd	512 Peach St	512 Peach St
-----------------------	--------------	--------------

(City, State, Zip) *	(City, State, Zip)	(City, State, Zip)
----------------------	--------------------	--------------------

Fort Worth, TX 76134-3629	Crowley, TX 76036-3119	Crowley, TX 76036-3119
---------------------------	------------------------	------------------------

LOCATION PHONE: 817-297-5942	OWNER PHONE: 817-297-5942	CONTACT NAME: Kathryn Blackman
------------------------------	---------------------------	--------------------------------

OBJECT LOCATION: *	OWNER EMAIL:	CONTACT PHONE: 817-297-5942
--------------------	--------------	-----------------------------

Boiler Room	Nature of Business: School	CONTACT EMAIL: kathryn.blackman@crowley.k12.t
-------------	----------------------------	---

MANUFACTURER *	NATL BOARD #	SERIAL NUMBER	MFGR MODEL #
WEIL MCLAIN	000000	BG994WF	BG994WF

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
75	1980	24	Cast Iron	Hot Water Heating			2320-LB/HR		H

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE			FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST *	TOTAL CAP. *	# OF SAFETIES	<input type="checkbox"/> PROBE TYPE	<input checked="" type="checkbox"/> FLOAT & CHAMBER	Natural Gas	2800000	BTU/HR OUTPUT
75	2675000	1	<input type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____			
LOWEST * 75		<input checked="" type="checkbox"/> BTU/HR	<input type="checkbox"/> #/HR	MAWP: 150			

EXPANSION TANK ASME * <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	EXPANSION TANK MAWP 125	EXTERNAL PIPE ASME <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A
--	-------------------------	---

EXTENSION INSPECTION? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
---	---

Comments: Boiler Room has storage which should be removed. 3/01/2017.

Boiler still needs feed water to be disconnected to complete disconnection process. 3/01/2017.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)
1 - 65.206(a)	COND: Boiler access obstructed.
2 - 65.600(a)	COND: Conditions not covered by the rules. Explain condition.

See Supplemental Report for complete list of open violations

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.

SIGNATURE OF INSPECTOR

Christopher Monroe

2060

TX COMMISSION #

INSPECTION ORG.

Robert Green

SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION \*

03/01/2017

DATE (MM/DD/YY) \*

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? *	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	(IF NO, EXPLAIN FULLY UNDER VIOLATIONS)
---	---	---



# TEXAS DEPARTMENT OF LICENSING AND REGULATION

Licensing Division  
(512) 463-6599 - (800) 803-9202  
Fax (512) 475-2871 CSBoiler@TDLR.Texas.gov

Technical  
(512) 539-5716  
Boilers@TDLR.Texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

## Boiler Equipment Report of Inspection - Supplemental Report

TX # TX078591

Date: 03/01/2017

Location Name Sycamore Elementary School - Crowley CISD

Object Address 512 Peach St, Crowley, TX 76036-3119

Location On Site Boiler Room

### Comments:

Boiler Room has storage which should be removed. 3/01/2017.

Boiler still needs feed water to be disconnected to complete disconnection process. 3/01/2017.

### Remarks:

1 - 65.206(a) COND: Boiler access obstructed.

65.206(a) - Accumulation of rubbish and materials. 3/01/2017.

2 - 65.600(a) COND: Conditions not covered by the rules. Explain condition.

Boiler still needs feed water to be disconnected to complete disconnection process. 3/01/2017.

Name of Authorized/Deputy Inspector Christopher Monroe Signature \_\_\_\_\_

Inspection Organization \_\_\_\_\_ TX COMMISSION # 2060 Date 03/01/2017

Owner/Operator Crowley CISD Title \_\_\_\_\_  
Name