

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-638-2727 and /or via email at boilers@tdlr.texas.gov.

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.tdlr.texas.gov

FOR CERTIFICATE QUESTIONS

Email: csboiler@tdlr.texas.gov

(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@tdlr.texas.gov

512-539-5716

CALPINE CORPORATION BOSQUE ENERGY CENTER
DEAN THRALL PLANT MGR
PO BOX 5436
LAGUNA PARK TX 76644-5436

BOILER CERTIFICATE OF OPERATION

Inspection Type:
Internal

Date of Inspection:
May 14, 2015

Certificate Expiration
May 14, 2016

Texas Boiler Number:
TX192095

Manufacturer:
Alstom

National Board Number:
024151

Manufacturer's Serial Number:
66008400

Pressure Allowed: **2125** psig

S/SR Valve Setpoint: **2189** psig

LOCATION:

CALPINE CORPORATION-BOSQUE
ENERGY CENTER
557 BOSQUE COUNTY ROAD 3610
LAGUNA PARK, TX 76644-5436

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.


William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201507240017**