

## CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

### IMPORTANT ACCIDENT INFORMATION:

**In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and /or via email at [boilers@license.state.tx.us](mailto:boilers@license.state.tx.us).**

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

**Web site: [www.tdlr.texas.gov](http://www.tdlr.texas.gov)**

#### FOR CERTIFICATE QUESTIONS

**Email:** [csboiler@tdlr.texas.gov](mailto:csboiler@tdlr.texas.gov)  
(800) 722-7843 or (512) 539-5707

#### FOR TECHNICAL QUESTIONS

**Email:** [boilers@license.state.tx.us](mailto:boilers@license.state.tx.us)  
(512) 539-5717

CALPINE CORPORATION BOSQUE ENERGY CENTER  
DEAN THRALL PLANT MGR  
557 BOSQUE COUNTY RD 3610  
LAGUNA PARK TX 766445436

# BOILER CERTIFICATE OF OPERATION

Inspection Type:  
**Internal**

Date of Inspection:  
**March 05, 2014**

Certificate Expiration  
**March 05, 2015**

Texas Boiler Number:  
**TX192095**

Manufacturer:  
**Alstom**

National Board Number:  
**024151**

Manufacturer's Serial Number:  
**66008400**

Pressure Allowed: **2125** psig

S/SR Valve Setpoint: **2189** psig

#### LOCATION:

CALPINE CORPORATION-BOSQUE  
ENERGY CENTER  
557 BOSQUE COUNTY ROAD 3610 PO  
BOX 5436  
LAGUNA PARK, TX 76644-5436

**The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.**

  
William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201403280074**