TEXAS DEPARTMENT OF LICENSING AND REGULATION

Licensing Division	Technical
(512) 463-6599 - (800) 803-9202	(512) 539-5716
Fax (512) 475-2871 csboiler@tdlr.texas.gov	boilers@tdlr.texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# *	*		STATUS: *	
TX260053	☐ 1ST INSPECTION ☑ SUBSEQUENT	☑ INTERNAL ☐ EXTERNAL ☐ NON-CERTIFICATE	☑ ACTIVE ☐ DISCONNECTED IN PLACE ☐ EXEMPT ☐ JUNKED ☐ DISPOSITION UNKNOWN	☑ NEW ☐ 2ND HAND

IDENTIFIED BY: * ☑ DECAL ☐ STAMP ☐ TAG | VARIANCE: * ☐ YES ☑ NO | TEXAS SPECIAL: * ☐ YES ☑ NO

PHYSICAL ADDRESS (if the physical address has changed a first inspection is required)	OWNER ADDRESS	MAILING ADDRESS
NAME * **United Laboratories Manufacturing LLC**	NAME **UNITED ONE INTERNATIONAL LABS**	NAME **United Laboratories Manufacturing LLC**
(Address 1) * **1541 Champion Drive**	(Address 1) **1541 Champion Dr**	(Address 1) **1541 Champion Dr**
(City, State, Zip) * **Carrollton, TX 75006-6814**	(City, State, Zip) **Carrollton, TX 75006-6814**	(City, State, Zip) **Carrollton, TX 75006-6814**
LOCATION PHONE: **972-490-3300**	OWNER PHONE: **(972)490-3300**	CONTACT NAME: **Tyson Thurman**
OBJECT LOCATION: * **PRODUCTION**	OWNER EMAIL: **jgibson@united1labs.com**	CONTACT PHONE: **469 865-3360**
	Nature of Business: **Manufacture**	CONTACT EMAIL: **tthurman@united1Labs.com**

MANUFACTURER *	NAT'L BOARD #	SERIAL NUMBER	MFGR MODEL #
PACIFIC STEAM	**12769**	**12769**	**PSE36**

Boiler MAWP*	YEAR BUILT *	INTERVAL*	BLR TYPE *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
100	**2013**	**12**	**Electric**	**Power**	**14**		**LB/HR**	**122-LB/HR**	**M**

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE	FUEL *	BTU/HR INPUT
SET PRESSURE	TOTAL CAP. *	# OF SAFETIES	☐ PROBE TYPE ☑ FLOAT & CHAMBER	**Electricity**	**126000**
HIGHEST* **100**	**644**	**1**	☐ FLOW SWITCH ☐ OTHER _____		BTU/HR OUTPUT
LOWEST * **100**		☐ BTU/HR ☑ #/HR	MAWP: **150**		

EXPANSION TANK ASME * ☐ YES ☐ NO ☑ N/A | EXPANSION TANK MAWP | EXTERNAL PIPE ASME ☑ YES ☐ NO ☐ N/A

EXTENSION INSPECTION? ☐ YES ☐ NO | EXTENSION APPROVAL DATE (IF APPLICABLE)

Comments:

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.

SIGNATURE OF INSPECTOR (Jeffery Clark)	2014 TX COMMISSION #	0006 INSPECTION ORG.
Tyson Thurman SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION*	09/25/2016 DATE (MM/DD/YY) *	

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED?* ☑ YES ☐ NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)