

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and /or via email at boilers@license.state.tx.us.

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.tdlr.texas.gov

FOR CERTIFICATE QUESTIONS

Email: csboiler@tdlr.texas.gov
(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@license.state.tx.us
(512) 539-5717

UNITED LABORATORIES MANUFACTURING LLC
TYSON THURMAN MAINTENANCE MANAGER
1541 CHAMPION DR
CARROLLTON TX 75006-6814

BOILER CERTIFICATE OF OPERATION

Inspection Type:
Internal

Date of Inspection:
April 22, 2015

Certificate Expiration
April 22, 2016

Texas Boiler Number:
TX260053

Manufacturer:
PACIFIC STEAM

National Board Number:
12769

Manufacturer's Serial Number:
12769

Pressure Allowed: **100** psig

S/SR Valve Setpoint: **100** psig

LOCATION:

UNITED LABORATORIES
MANUFACTURING LLC
1541 CHAMPION DRIVE
CARROLLTON, TX 75006-6814

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.


William H. Kuntz, Executive Director

CERTIFICATE NUMBER: 201505180115