

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and/or via email at

boilers@license.state.tx.us

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.license.state.tx.us

FOR CERTIFICATE QUESTIONS

Email: CSBoiler@license.state.tx.us

(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@license.state.tx.us

(512) 539-5717

SYCAMORE ELEMENTARY SCHOOL
1601 COUNTRY MANOR ROAD
FORT WORTH TX 76134

BOILER CERTIFICATE OF OPERATION

Inspection Type:
EXTERNAL

Date of Inspection:
AUGUST 03 2010

Certificate Expiration Date:
AUGUST 03 2012

Location:
SYCAMORE ELEMENTARY SCHOOL
1601 COUNTRY MANOR ROAD
FORT WORTH TX 76134

Texas Boiler Number:

78591

Manufacturer:
WEIL MCLAIN

National Board Number:
000000

Manufacturer's Serial Number:
BG994WF

Pressure Allowed: **30** psig

S/SR Valve Setpoint: **30** psig

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.



William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201009150018**