



TEXAS DEPARTMENT OF LICENSING & REGULATION

Regulatory Program Management Division • PO Box 12157 • Austin, Texas 78711 • (512) 463-6599

www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX235866	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input checked="" type="checkbox"/> INTERNAL <input type="checkbox"/> EXTERNAL <input type="checkbox"/> NON-CERTIFICATE	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> EXEMPT <input type="checkbox"/> NEW <input type="checkbox"/> JUNKED <input type="checkbox"/> DISPOSITION UNKNOWN <input type="checkbox"/> 2ND HAND
-------------------	---	--	--

IDENTIFIED BY: * <input checked="" type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME * Star Brite Cleaners	NAME Star Brite Cleaners	NAME Star Brite Cleaners
--------------------------------------	------------------------------------	------------------------------------

(Address 1) * 692 S Walnut Ave	(Address 1) 692 S Walnut Ave	(Address 1) 692 S Walnut Ave
--	--	--

(City, State, Zip) * New Braunfels, TX 78130-5723	(City, State, Zip) New Braunfels, TX 78130-5723	(City, State, Zip) New Braunfels, TX 78130-5723
---	---	---

LOCATION PHONE: 830-237-2376	OWNER PHONE: 830-237-2376	CONTACT NAME: Bryan Foreman
-------------------------------------	----------------------------------	------------------------------------

OBJECT LOCATION: *	BUSINESS EMAIL: bryanforeman@gmail.com	CONTACT PHONE: 830-237-2376
BOILER ROOM	Nature of Business: Cleaners	BUSINESS EMAIL: bryanforeman@gmail.com

MANUFACTURER * FULTON BOILER	NAT'L BOARD # 104786	SERIAL NUMBER 104786	MFGR MODEL # FB 030
--	--------------------------------	--------------------------------	-------------------------------

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE CLASS *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
150	2007	12	Fire Tube	Power Boiler	Steam Greater than 15 PSI	90			1035-LB/HR	S


SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST * 150	TOTAL CAP. * 2585	# OF SAFETIES 1	<input checked="" type="checkbox"/> PROBE TYPE	<input type="checkbox"/> FLOAT & CHAMBER	Natural Gas	1260000
LOWEST * 150	<input type="checkbox"/> BTU/HR	<input checked="" type="checkbox"/> #/HR	<input type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____		BTU/HR OUTPUT 1035000
EXPANSION TANK ASME * <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A			EXPANSION TANK MAWP 150		EXTERNAL PIPE ASME <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	

EXTENSION INSPECTION? <input type="checkbox"/> YES <input type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
--	---

Comments: Sight glass replaced, both feed pumps check valves replaced. Watersides clean, amount of soft deposits decreased since last inspection.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.


 SIGNATURE OF INSPECTOR
 Kevin Decker

1871
 TX COMMISSION #

Cincinnati Insurance Company
 INSPECTION ORG.

Bryan Foreman, Owner 202-281-4646
 SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION *

02/17/2023
 DATE (MM/DD/YY) *

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? * YES NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)