

## CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

### IMPORTANT ACCIDENT INFORMATION:

**In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and/or via email at**

[boilers@license.state.tx.us](mailto:boilers@license.state.tx.us)

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

**Web site: [www.license.state.tx.us](http://www.license.state.tx.us)**

#### FOR CERTIFICATE QUESTIONS

**Email:** [CSBoiler@license.state.tx.us](mailto:CSBoiler@license.state.tx.us)

(800) 722-7843 or (512) 539-5707

#### FOR TECHNICAL QUESTIONS

**Email:** [boilers@license.state.tx.us](mailto:boilers@license.state.tx.us)

(512) 539-5717

BOSQUE POWER COMPANY LLC  
557 BOSQUE COUNTY ROAD 3610  
LAGUNA PARK TX 76634

# BOILER CERTIFICATE OF OPERATION

Inspection Type:  
**INTERNAL**

Date of Inspection:  
**APRIL 05 2012**

Certificate Expiration Date:  
**APRIL 05 2013**

Location:

BOSQUE POWER COMPANY LLC  
557 BOSQUE COUNTY ROAD 3610  
LAGUNA PARK TX 76634

Texas Boiler Number:

**192095**

Manufacturer:

**ALSTOM POWER**

National Board Number:

**024151**

Manufacturer's Serial Number:

**66008400**

Pressure Allowed: **2,125** psig

S/SR Valve Setpoint: **2,125** psig

**The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.**



William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201205160089**