

### **CERTIFICATE POSTING REQUIREMENTS**

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

### **IMPORTANT ACCIDENT INFORMATION:**

**In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-638-2727 and /or via email at [boilers@tdlr.texas.gov](mailto:boilers@tdlr.texas.gov).**

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

**Web site: [www.tdlr.texas.gov](http://www.tdlr.texas.gov)**

#### **FOR CERTIFICATE QUESTIONS**

**Email:** [csboiler@tdlr.texas.gov](mailto:csboiler@tdlr.texas.gov)

**(800) 722-7843 or (512) 539-5707**

#### **FOR TECHNICAL QUESTIONS**

**Email:** [boilers@tdlr.texas.gov](mailto:boilers@tdlr.texas.gov)

**512-539-5716**

STAR BRITE CLEANERS  
BRIAN FOREMAN  
692 S WALNUT AVE  
NEW BRAUNFELS TX 78130-5723

## **BOILER CERTIFICATE OF OPERATION**

Inspection Type:  
**Internal**

Date of Inspection:  
**December 15, 2016**

Certificate Expiration  
**December 15, 2017**

Texas Boiler Number:  
**TX235866**

Manufacturer:  
**FULTON BOILER**

National Board Number:  
**104786**

Manufacturer's Serial Number:  
**104786**


Pressure Allowed: **150** psig

S/SR Valve Setpoint: **150** psig

#### **LOCATION:**

STAR BRITE CLEANERS  
692 S WALNUT AVE  
NEW BRAUNFELS, TX 78130-5723

**The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.**



Brian Francis, Executive Director

**CERTIFICATE NUMBER: 201704040171**