



# TEXAS DEPARTMENT OF LICENSING AND REGULATION

**Licensing Division**  
 (512) 463-6599 - (800) 803-9202  
 Fax (512) 475-2871 csboiler@tdlr.texas.gov

**Technical**  
 (512) 539-5716  
 boilers@tdlr.texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

## Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX215554	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input type="checkbox"/> INTERNAL <input type="checkbox"/> NON-CERTIFICATE	<input checked="" type="checkbox"/> EXTERNAL	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> JUNKED	<input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> DISPOSITION UNKNOWN	<input type="checkbox"/> EXEMPT <input type="checkbox"/> NEW <input type="checkbox"/> 2ND HAND
-------------------	---	---	--	---	--	--

IDENTIFIED BY: * <input checked="" type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME * <b>Shiloh Village Apartments</b>	NAME <b>SHILOH VILLAGE APARTMENTS</b>	NAME <b>SHILOH VILLAGE APARTMENTS</b>
--	--	--

(Address 1) * <b>8702 Shiloh Rd</b>	(Address 1) <b>ATTN: PROPERTY MANAGER 8702 SHILOH RD</b>	(Address 1) <b>ATTN: PROPERTY MANAGER 8702 SHILOH RD</b>
--	---	---

(City, State, Zip) * <b>Dallas, TX 75228-4568</b>	(City, State, Zip) <b>DALLAS, TX 75228</b>	(City, State, Zip) <b>DALLAS, TX 75228</b>
--	---	---

LOCATION PHONE:	OWNER PHONE: <b>2143282632</b>	CONTACT NAME: <b>SHILOH VILLAGE APARTMEN</b>
-----------------	--------------------------------	--

OBJECT LOCATION: * <b>BOILER ROOM</b>	OWNER EMAIL:	CONTACT PHONE: <b>2143282632</b>
	Nature of Business:	CONTACT EMAIL:

MANUFACTURER * <b>RAYPAK INC</b>	NAT'L BOARD # <b>174252</b>	SERIAL NUMBER <b>0008174252</b>	MFGR MODEL # <b>W 3 - 0514</b>
-------------------------------------	--------------------------------	------------------------------------	-----------------------------------

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
<b>160</b>	<b>2000</b>	<b>36</b>	<b>Water Tube</b>	<b>Hot Water Supply</b>	<b>43</b>		<b>514-LB/HR</b>		<b>H</b>

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST * <b>125</b>	TOTAL CAP. * <b>2070000</b>	# OF SAFETIES <b>1</b>	<input type="checkbox"/> PROBE TYPE	<input type="checkbox"/> FLOAT & CHAMBER	<b>Natural Gas</b>	<b>511500</b>
LOWEST * <b>125</b>	<input checked="" type="checkbox"/> BTU/HR <input type="checkbox"/> #/HR		<input checked="" type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____		BTU/HR OUTPUT <b>419430</b>
EXPANSION TANK ASME * <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A			EXPANSION TANK MAWP <b>160</b>		EXTERNAL PIPE ASME <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> N/A	

EXTENSION INSPECTION? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
---	---

Comments: V (1) STACK TO SHORT NEEDS TO EXTEND ABOVE ROOF LINE.

CO -0

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)
1 - 65.602	COND: Chimneys and/or vents do not conform to manufacturers recommendations. (continued on Supplemental Report...)

See Supplemental Report for complete list of open violations

**I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.**

*Don Crow*  
 \_\_\_\_\_  
 SIGNATURE OF INSPECTOR  
 Don Crow

1797  
 \_\_\_\_\_  
 TX COMMISSION #

TDLR  
 \_\_\_\_\_  
 INSPECTION ORG.

JAUN REYEZ  
 \_\_\_\_\_  
 SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION \*

07/11/2016  
 \_\_\_\_\_  
 DATE (MM/DD/YY) \*

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? \*  YES  NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)



# TEXAS DEPARTMENT OF LICENSING AND REGULATION

Licensing Division  
(512) 463-6599 - (800) 803-9202  
Fax (512) 475-2871 CSBoiler@TDLR.Texas.gov

Technical  
(512) 539-5716  
Boilers@TDLR.Texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

## Boiler Equipment Report of Inspection - Supplemental Report

TX # **TX215554** Date: **07/11/2016**  
Location Name **Shiloh Village Apartments**  
Object Address **ATTN: PROPERTY MANAGER 8702 SHILOH RD , DALLAS , TX 75228**  
Location On Site **BOILER ROOM**

Comments:  
V (1) STACK TO SHORT NEEDS TO EXTEND ABOVE ROOF LINE.

CO -0

Remarks:  
1 - 65.602 COND: Chimneys and/or vents do not conform to manufacturers recommendations.

Name of Authorized/Deputy Inspector Don Crow Signature *Don Crow*  
Inspection Organization TDLR TX COMMISSION # 1797 Date 07/11/2016  
Owner/Operator SHILOH VILLAGE APARTMENTS Title \_\_\_\_\_  
Name