



# TEXAS DEPARTMENT OF LICENSING & REGULATION

Regulatory Program Management Division • PO Box 12157 • Austin, Texas 78711 • (512) 463-6599

www.tdlr.texas.gov

## Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX286439	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input checked="" type="checkbox"/> INTERNAL <input type="checkbox"/> EXTERNAL <input type="checkbox"/> NON-CERTIFICATE	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> EXEMPT <input type="checkbox"/> JUNKED <input type="checkbox"/> DISPOSITION UNKNOWN	<input checked="" type="checkbox"/> NEW <input type="checkbox"/> 2ND HAND
-------------------	---	--	---	--

IDENTIFIED BY: * <input checked="" type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME * <b>Vip Cleaners</b>	NAME <b>VIP CLEANERS-NACOGDOCHES</b>	NAME <b>VIP CLEANERS-NACOGDOCHES</b>
-------------------------------	---	---

(Address 1) * <b>4515 North St Ste 1</b>	(Address 1) <b>ATTN: OWNER 4515 NORTH STREET SUITE 1</b>	(Address 1) <b>ATTN: OWNER 4515 NORTH STREET SUITE 1</b>
---	---	---

(City, State, Zip) * <b>Nacogdoches, TX 75965-1811</b>	(City, State, Zip) <b>NACOGDOCHES, TX 75965</b>	(City, State, Zip) <b>NACOGDOCHES, TX 75965</b>
---	--	--

LOCATION PHONE:	OWNER PHONE: <b>9362055910</b>	CONTACT NAME: <b>VIP CLEANERS-NACOGDOCHI</b>
-----------------	--------------------------------	--

OBJECT LOCATION: * <b>Boiler Room</b>	BUSINESS EMAIL: <b>planetxskate@aol.com</b>	CONTACT PHONE: <b>9362055910</b>
	Nature of Business: <b>Cleaners</b>	BUSINESS EMAIL: <b>planetxskate@aol.com</b>

MANUFACTURER * <b>Fulton</b>	NAT'L BOARD # <b>125236</b>	SERIAL NUMBER <b>F2014574A</b>	MFGR MODEL # <b>FB-020-LE</b>
---------------------------------	--------------------------------	-----------------------------------	----------------------------------

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE CLASS *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
150	2020	12	Fire Tube	Power Boiler	Steam Greater than 15 PSI	60		690-LB/HR	690-LB/HR	S

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST * <b>150</b>	TOTAL CAP. * <b>1656</b>	# OF SAFETIES <b>1</b>	<input checked="" type="checkbox"/> PROBE TYPE	<input type="checkbox"/> FLOAT & CHAMBER	<b>Methane</b>	<b>807000</b>
LOWEST * <b>150</b>	<input checked="" type="checkbox"/> BTU/HR	<input type="checkbox"/> #/HR	<input type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____		<b>BTU/HR OUTPUT</b> <b>670000</b>
EXPANSION TANK ASME * <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A			EXPANSION TANK MAWP		EXTERNAL PIPE ASME <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	

EXTENSION INSPECTION? <input type="checkbox"/> YES <input type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
--	---

Comments: CO monitor not installed yet. B-vent used and shows signs of leaking. CO 0 ppm.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)
1 - 65.602	COND: Chimneys and/or vents do not conform to manufacturers recommendations. (continued on Supplemental Report...)

See Supplemental Report for complete list of open violations

**I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.**

*Tim Adams*  
\_\_\_\_\_  
SIGNATURE OF INSPECTOR  
Timothy Adams

1864  
\_\_\_\_\_  
TX COMMISSION #

TDLR  
\_\_\_\_\_  
INSPECTION ORG.

Owner  
\_\_\_\_\_  
SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION \*

09/21/2022  
\_\_\_\_\_  
DATE (MM/DD/YY) \*

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? \*  YES  NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)



# TEXAS DEPARTMENT OF LICENSING AND REGULATION

Licensing Division  
(512) 463-6599 - (800) 803-9202  
Fax (512) 475-2871 CSBoiler@TDLR.Texas.gov

Technical  
(512) 539-5716  
Boilers@TDLR.Texas.gov

P.O. Box 12157 - Austin, Texas 78711 - www.tdlr.texas.gov

## Boiler Equipment Report of Inspection - Supplemental Report

TX # **TX286439** Date: **09/21/2022**  
Location Name **Vip Cleaners**  
Object Address **ATTN: OWNER 4515 NORTH STREET SUITE 1 , NACOGDOCHES , TX 75965**  
Location On Site **Boiler Room**

Comments:  
CO monitor not installed yet. B-vent used and shows signs of leaking. CO 0 ppm.

Remarks:  
1 - 65.602 COND: Chimneys and/or vents do not conform to manufacturers recommendations.

Name of Authorized/Deputy Inspector Timothy Adams Signature *Tim Adams*  
Inspection Organization TDLR TX COMMISSION # 1864 Date 09/21/2022  
Owner/Operator VIP CLEANERS-NACOGDOCHES Title \_\_\_\_\_  
Name