

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-638-2727 and/or via email at

boilers@tdlr.texas.gov

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.tdlr.texas.gov

FOR CERTIFICATE QUESTIONS

Email: CSBoiler@tdlr.texas.gov
(800) 803-9202 or (512) 463-6599

FOR TECHNICAL QUESTIONS

Email: boilers@tdlr.texas.gov
(512) 539-5716

**SHILOH VILLAGE APARTMENTS
8702 SHILOH RD
DALLAS TX 75228**

BOILER CERTIFICATE OF OPERATION

**Inspection Type:
EXTERNAL**

**Date of Inspection:
JULY 31 2013**

**Certificate Expiration Date:
JULY 31 2016**

**Location:
SHILOH VILLAGE APARTMENTS
8702 SHILOH RD
DALLAS TX 75228**

Texas Boiler Number:

215554


**Manufacturer:
RAYPAK INC**

**National Board Number:
174252**

**Manufacturer's Serial Number:
0008174252**

**Pressure Allowed: 125 psig
S/SR Valve Setpoint: 125 psig**

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.


William H. Kuntz, Executive Director

CERTIFICATE NUMBER: 201309050212