



TEXAS DEPARTMENT OF LICENSING & REGULATION

Regulatory Program Management Division • PO Box 12157 • Austin, Texas 78711 • (512) 463-6599

www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX239271	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input checked="" type="checkbox"/> INTERNAL <input type="checkbox"/> EXTERNAL <input type="checkbox"/> NON-CERTIFICATE	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> EXEMPT <input type="checkbox"/> JUNKED <input type="checkbox"/> DISPOSITION UNKNOWN	<input checked="" type="checkbox"/> NEW <input type="checkbox"/> 2ND HAND
-------------------	---	--	---	--

IDENTIFIED BY: * <input checked="" type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME * Victoria WLE, LP	NAME Victoria WLE, LP	NAME Victoria WLE, LP
-----------------------------------	---------------------------------	---------------------------------

(Address 1) * 1205 S. Bottom Street	(Address 1) 1205 Bottom St	(Address 1) 1205 Bottom St
---	--------------------------------------	--------------------------------------

(City, State, Zip) * Victoria, TX 77901-9161	(City, State, Zip) Victoria, TX 77901-9161	(City, State, Zip) Victoria, TX 77901-9161
--	--	--

LOCATION PHONE: (361) 489-3719 Alex Benavides	OWNER PHONE: (361) 484-0310	CONTACT NAME: Jason Hixson
--	------------------------------------	-----------------------------------

OBJECT LOCATION: * HRSO LP	BUSINESS EMAIL: jhixson@victoriawlepower.com	CONTACT PHONE: (361) 484-0310
--------------------------------------	---	--------------------------------------

	Nature of Business: Utility	BUSINESS EMAIL: jhixson@victoriawlepower.com
--	------------------------------------	---

MANUFACTURER * Thermal Engineering Int.	NAT'L BOARD # 000584	SERIAL NUMBER 17405-1C	MFGR MODEL #
---	--------------------------------	----------------------------------	--------------

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE CLASS *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
150	2003	12	Unfired	Power Boiler	Steam Greater than 15 PSI	623485			64073-LB/HR	S

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST * 154	TOTAL CAP. * 65622	# OF SAFETIES 3	<input type="checkbox"/> PROBE TYPE	<input type="checkbox"/> FLOAT & CHAMBER	Recovered Heat	BTU/HR OUTPUT
LOWEST * 145	<input type="checkbox"/> BTU/HR	<input checked="" type="checkbox"/> #/HR	<input type="checkbox"/> FLOW SWITCH	<input checked="" type="checkbox"/> OTHER Transmitter		
EXPANSION TANK ASME * <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A			EXPANSION TANK MAWP		EXTERNAL PIPE ASME <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A	

EXTENSION INSPECTION? <input type="checkbox"/> YES <input type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
--	---

Comments: Internal inspection proved no adverse conditions or defects in either the fireside or the waterside. Externally and internally, there are no noticeable bumps bulges or blisters. Internal surfaces had minimal scale. Overall conditions were satisfactory.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)
-------------------	--

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.

Manuel Del Bosque

SIGNATURE OF INSPECTOR

Manuel Del Bosque

1816

TX COMMISSION #

ARISE Incorporated

INSPECTION ORG.

David Hernandez, Maintenance

SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION *

10/26/2022

DATE (MM/DD/YY) *

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? *	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	(IF NO, EXPLAIN FULLY UNDER VIOLATIONS)
---	---	---