

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and/or via email at

boilers@license.state.tx.us

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.license.state.tx.us

FOR CERTIFICATE QUESTIONS

Email: CSBoiler@license.state.tx.us

(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@license.state.tx.us

(512) 539-5717

ATRIA COMMUNITIES
3975 WILLIAM D TATE
GRAPEVINE TX 76051

BOILER CERTIFICATE OF OPERATION

Inspection Type:
EXTERNAL

Date of Inspection:
DECEMBER 17 2012

Certificate Expiration Date:
DECEMBER 17 2015

Location:
ATRIA COMMUNITIES
3975 WILLIAM D TATE
GRAPEVINE TX 76051

Texas Boiler Number:

237621

Manufacturer:

AO SMITH WATER

National Board Number:

025115

Manufacturer's Serial Number:

0925M000005

Pressure Allowed: **125** psig

S/SR Valve Setpoint: **125** psig

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.



William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201301310088**