



TEXAS DEPARTMENT OF LICENSING & REGULATION

Regulatory Program Management Division • PO Box 12157 • Austin, Texas 78711 • (512) 463-6599

www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX100229	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input checked="" type="checkbox"/> INTERNAL <input type="checkbox"/> EXTERNAL <input type="checkbox"/> NON-CERTIFICATE	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> EXEMPT <input type="checkbox"/> JUNKED <input type="checkbox"/> DISPOSITION UNKNOWN	<input checked="" type="checkbox"/> NEW <input type="checkbox"/> 2ND HAND
-------------------	---	--	---	--

IDENTIFIED BY: * <input type="checkbox"/> DECAL <input checked="" type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME *	NAME	NAME
--------	------	------

NRG Energy - W.A. Parish Generating Station **NRG Energy - W.A. Parish Generating Station** **NRG Energy - W.A. Parish Generating Station**

(Address 1) * (Address 1) (Address 1)

2500 Y U Jones Rd **12307 Kurland Dr** **12307 Kurland Dr**

(City, State, Zip) * (City, State, Zip) (City, State, Zip)

Richmond, TX 77469-3558 **Houston, TX 77034-4811** **Houston, TX 77034-4811**

LOCATION PHONE: **(281) 343-2475 Edwin James** OWNER PHONE: **(281) 782-4972** CONTACT NAME: **NRG Energy - W.A. Parish Gener**

OBJECT LOCATION: * BUSINESS EMAIL: **tom.white@nrgenergy.com** CONTACT PHONE: **(281) 782-4972**

WAP 6 (PG at Level 14) Nature of Business: **Utility** BUSINESS EMAIL: **tom.white@nrgenergy.com**

MANUFACTURER *	NAT'L BOARD #	SERIAL NUMBER	MFGR MODEL #
----------------	---------------	---------------	--------------

Babcock & Wilcox **024058** **BW-24058**

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE CLASS *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
2950	1976	12	Water Tube	Power Boiler	Steam Greater than 15 PSI	564077			4750000-LB/HR	S

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
--------------------------	--	--	-----------------------	--	--------	--------------

SET PRESSURE HIGHEST *	TOTAL CAP. *	# OF SAFETIES	<input type="checkbox"/> PROBE TYPE	<input type="checkbox"/> FLOAT & CHAMBER	Coal	BTU/HR OUTPUT
LOWEST *	5509701	10	<input type="checkbox"/> FLOW SWITCH	<input checked="" type="checkbox"/> OTHER Transmitter		
2950		<input type="checkbox"/> BTU/HR <input checked="" type="checkbox"/> #/HR	MAWP: 3000			

EXPANSION TANK ASME * YES NO N/A EXPANSION TANK MAWP EXTERNAL PIPE ASME YES NO N/A

EXTENSION INSPECTION? YES NO EXTENSION APPROVAL DATE (IF APPLICABLE)

Comments: Satisfactory internal certificate inspection. No adverse conditions found.

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.

Manuel Del Bosque

SIGNATURE OF INSPECTOR
Manuel Del Bosque

1816
TX COMMISSION #

ARISE Incorporated
INSPECTION ORG.

Ricky Quirk, NDIC Inspector, (281) 343-2475
SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION *

03/08/2021
DATE (MM/DD/YY) *

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? * YES NO (IF NO, EXPLAIN FULLY UNDER VIOLATIONS)