



TEXAS DEPARTMENT OF LICENSING & REGULATION

Regulatory Program Management Division • PO Box 12157 • Austin, Texas 78711 • (512) 463-6599

www.tdlr.texas.gov

Boiler Equipment Report of Inspection

PURSUANT TO CHAPTER 755, HEALTH AND SAFETY CODE, 16 TX ADMINISTRATIVE CODE, CHAPTER 65, AND OCCUPATIONS CODE CHAPTER 51

TX# * TX277097	* <input type="checkbox"/> 1ST INSPECTION <input checked="" type="checkbox"/> SUBSEQUENT	<input checked="" type="checkbox"/> INTERNAL <input type="checkbox"/> EXTERNAL <input type="checkbox"/> NON-CERTIFICATE	STATUS: * <input checked="" type="checkbox"/> ACTIVE <input type="checkbox"/> DISCONNECTED IN PLACE <input type="checkbox"/> EXEMPT <input type="checkbox"/> JUNKED <input type="checkbox"/> DISPOSITION UNKNOWN	<input checked="" type="checkbox"/> NEW <input type="checkbox"/> 2ND HAND
-------------------	---	--	---	--

IDENTIFIED BY: * <input checked="" type="checkbox"/> DECAL <input type="checkbox"/> STAMP <input type="checkbox"/> TAG	VARIANCE: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	TEXAS SPECIAL: * <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
--	---	--

PHYSICAL ADDRESS <small>(if the physical address has changed a first inspection is required)</small>	OWNER ADDRESS	MAILING ADDRESS
---	---------------	-----------------

NAME * Blue Triton Brands	NAME Blue Triton Brands	NAME Nestle USA - Nestle Waters North America
-------------------------------------	-----------------------------------	---

(Address 1) * 4718 Mountain Creek Pkwy	(Address 1) 4718 Mountain Creek Pkwy	(Address 1) 4718 Mountain Creek Pkwy
--	--	--

(City, State, Zip) * Dallas, TX 75236-4604	(City, State, Zip) Dallas, TX 75236-4604	(City, State, Zip) Dallas, TX 75236-4604
--	--	--

LOCATION PHONE: 214.240.5284	OWNER PHONE:	CONTACT NAME: Joey Henderson
-------------------------------------	--------------	-------------------------------------

OBJECT LOCATION: * Boiler Room	BUSINESS EMAIL: Nature of Business: Food	CONTACT PHONE: BUSINESS EMAIL: michael.henderson@waters.nestle.
--	--	---

MANUFACTURER * Bryan	NAT'L BOARD # 061509	SERIAL NUMBER 102121	MFGR MODEL # RV 800 S 150 FDG LX
--------------------------------	--------------------------------	--------------------------------	--

Boiler MAWP *	YEAR BUILT *	INTERVAL *	BLR TYPE *	BLR USE CLASS *	BLR USE *	HEATING SURFACE	CAP (GAL)	MIN SRV	MAX STEAM	ASME STAMP *
150	2019	12	Water Tube	Power Boiler	Steam Greater than 15 PSI	972		7010		S

SAFETY RELIEF VALVE DATA			LOW WATER CUTOFF TYPE		FUEL *	BTU/HR INPUT
SET PRESSURE HIGHEST * 150	TOTAL CAP. * 10841	# OF SAFETIES 2	<input type="checkbox"/> PROBE TYPE	<input checked="" type="checkbox"/> FLOAT & CHAMBER	Natural Gas	8500000
LOWEST * 150	<input type="checkbox"/> BTU/HR	<input checked="" type="checkbox"/> #/HR	<input type="checkbox"/> FLOW SWITCH	<input type="checkbox"/> OTHER _____		BTU/HR OUTPUT 6800000

EXPANSION TANK ASME * <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A	EXPANSION TANK MAWP	EXTERNAL PIPE ASME <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A
--	---------------------	---

EXTENSION INSPECTION? <input type="checkbox"/> YES <input type="checkbox"/> NO	EXTENSION APPROVAL DATE (IF APPLICABLE)
--	---

Comments: Boiler temperature and pressure controls/gauges were inspected. Additionally, the boiler waterside, fireside, and fuel train were inspected. LWFCOs were removed and inspected. Log sheets were reviewed. No adverse conditions noted. -VDominguez

ITEM # - LAW/RULE	VIOLATION (ATTACH ADDITIONAL PAGES IF NECESSARY)

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT AS A RESULT OF MY INSPECTION.



 SIGNATURE OF INSPECTOR
 Vincent Dominguez

2139

 TX COMMISSION #

Zurich American Insurance Co

 INSPECTION ORG.

Michael Henderson

 SIGNATURE OF INDIVIDUAL PRESENT AT INSPECTION *

11/13/2021

 DATE (MM/DD/YY) *

IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED? *	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	(IF NO, EXPLAIN FULLY UNDER VIOLATIONS)
---	---	---