

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-638-2727 and /or via email at boilers@tdlr.texas.gov.

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.tdlr.texas.gov

FOR CERTIFICATE QUESTIONS

Email: csboiler@tdlr.texas.gov

(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@tdlr.texas.gov

512-539-5716

CITROFRUT USA LLC
ACCOUNTS PAYABLE
4200 W URSULA AVE
MCALLEN TX 78503-9025

BOILER CERTIFICATE OF OPERATION



Texas Boiler Number:
TX265518

Manufacturer:
Cleaver Brooks

National Board Number:
15718

Manufacturer's Serial Number:
M43475

Pressure Allowed: **150 psig**

S/SR Valve Setpoint: **150 psig**

Inspection Type:
Internal

Date of Inspection:
December 21, 2017

Certificate Expiration
December 21, 2018

LOCATION:

GRUPO PROEZA, S.A.P.I. DE C.V.
"CITROFRUT USA LLC"
4200 W URSULA AVE
MCALLEN, TX 78503-9025

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.

Brian Francis, Executive Director

CERTIFICATE NUMBER: **201801220204**