



ELBI-42065 HOME 2

Posting Requirements

For elevators, the certificate must be posted inside the car, or outside the car in the elevator lobby within 10 feet of the call button. Alternately, the certificate can be displayed in another area that is open to the public, but a plaque or notice indicating the location of the certificate must be posted in the elevator car or lobby. The letters on the notice must be at least 18-point font size. The notice must also state that the elevator is regulated by the Texas Department of Licensing and Regulation and list the Department's phone number, 800-803-9202, along with the building management's phone number. For escalators, the Certificate of Compliance must be posted in the escalator box. For other related equipment such as chairlifts or platform lifts, the certificate must be posted on the box containing the control circuitry.

The certificate below is designed to be cut out and displayed in a 5" x 7" frame.

Building Physical Location:

401 WYNHURST DRIVE
PLANO TX 75074

MIKE TESTERMAN
401 WYNHURST DR
PLANO TX 75074-8461

CERTIFICATE OF COMPLIANCE

For
Elevators, Escalators,
and Related Equipment



Decal Number:
96702

Date of Inspection:
FEBRUARY 06 2026

Next Inspection Due:
FEBRUARY 06 2027

Building Number: ELBI-42065
Building Name: HOME 2 SUITES PLANO
Contact Person: MIKE TESTERMAN
Building Owner: SHINN GATEWAY HOSPITALITY LTD
Equipment Description: PASSENGER

Waivers / Delays: See Below

Inspector's License Number: 20851

For information on waivers, delays, or violations found see: **Website:** www.tdlr.texas.gov/Elevator_SearchApp/

To report violations or complaints: **Phone:** 1-800-803-9202 **Website:** www.tdlr.texas.gov/Complaints/

THIS CERTIFICATE OF COMPLIANCE WAS ISSUED BY THE TEXAS DEPARTMENT OF LICENSING & REGULATION UNDER TEXAS HEALTH AND SAFETY CODE §754.016. THE ABOVE DESCRIBED EQUIPMENT HAS BEEN INSPECTED BY A CERTIFIED INSPECTOR AND FOUND TO BE IN COMPLIANCE EXCEPT FOR ANY DELAYS OR WAIVERS GRANTED BY THE EXECUTIVE DIRECTOR.

Date Signed: MARCH 11 2026

Courtney Arbour
Executive Director