

Posting Requirements

For elevators, the certificate must be posted inside the car, or outside the car in the elevator lobby within 10 feet of the call button. Alternately, the certificate can be displayed in another area that is open to the public, but a plaque or notice indicating the location of the certificate must be posted in the elevator car or lobby. The letters on the notice must be at least 18-point font size. The notice must also state that the elevator is regulated by the Texas Department of Licensing and Regulation and list the Department's phone number, 800-803-9202, along with the building management's phone number. For escalators, the Certificate of Compliance must be posted in the escalator box. For other related equipment such as chairlifts or platform lifts, the certificate must be posted on the box containing the control circuitry.

The certificate below is designed to be cut out and displayed in a 5" x 7" frame.

Building Physical Location:
6301 NORTH WEST LOOP 410
SAN ANTONIO TX 78238

JOSEPH TYLER
JC PENNEY
6501 LEGACY DR MS 2110
PLANO TX 75024-3612

CERTIFICATE OF COMPLIANCE

**For
Elevators, Escalators,
and Related Equipment**

Decal Number:
64672

Date of Inspection:
AUGUST 24 2017

Next Inspection Due:
AUGUST 24 2018

Building Number: ELBI-4991
Building Name: J C PENNEY-STORE 0631
Contact Person: JOSEPH TYLER
Building Owner: JC PENNEY COMPANY INC
Equipment Description: PASSENGER

Waivers / Delays: See Below

Inspector's License Number: 20071

For information on waivers, delays, or violations found see: **Website:** www.tdlr.texas.gov/Elevator_SearchApp/

To report violations or complaints: **Phone:** 1-800-803-9202 **Website:** www.tdlr.texas.gov/Complaints/

THIS CERTIFICATE OF COMPLIANCE WAS ISSUED BY THE TEXAS DEPARTMENT OF LICENSING & REGULATION UNDER TEXAS HEALTH AND SAFETY CODE §754.016. THE ABOVE DESCRIBED EQUIPMENT HAS BEEN INSPECTED BY A CERTIFIED INSPECTOR AND FOUND TO BE IN COMPLIANCE EXCEPT FOR ANY DELAYS OR WAIVERS GRANTED BY THE EXECUTIVE DIRECTOR.

Date Signed: SEPTEMBER 20 2017



Brian E. Francis
Executive Director