



# TEXAS DEPARTMENT OF LICENSING AND REGULATION

COMPLIANCE DIVISION—Elevator Program

P.O. Box 12157 - Austin, Texas 78711-2157 - (512) 463-6599 - (800) 803-9202 - Fax (512) 475-4870

Email: [elevators.escalators@license.state.tx.us](mailto:elevators.escalators@license.state.tx.us) - Web site: [www.license.state.tx.us](http://www.license.state.tx.us)

OCTOBER 08 2013

RODNEY BESEDA  
MD ANDERSON CANCER CENTER  
3000 PAWNEE ST UNIT 608  
HOUSTON TX 77054-3301

Building Location  
1901 EAST RD  
HOUSTON TX 77054

RE: M D ANDERSON - SCRB4  
ELBI: 35058  
Decal: 72424

We have received your request for a waiver/delay on correcting the a violation on your current elevator safety inspection. The material submitted with this request has been reviewed.

A waiver was requested for:

Code Rule:

A17.1 2.27.8 - Fire Service Key

**You have been granted a waiver.**

If you have any questions, you may contact us at 1-800-803-9202 or (512) 463-6599.

Sincerely,

Administrative Technician  
Compliance Division

**Pursuant to Administrative Rule 74.70(n) "(n) The building owner shall have copies of all current department issued waivers and delays, posted in the machine room/machinery space in a readily accessible and visible location available to elevator personnel."**