

1994 Texas Accessibility Standards
Technical Memorandum

**Texas Department of Licensing and Regulation
Architectural Barriers**

Issue Date: May 20, 1999

TM 99-13

**Scoping and Application
4.1.3(4)**

TAS 4.1.3(4) requires all interior and exterior stairs that connect levels that are not connected by an elevator, ramp, or other accessible means of vertical access to comply with TAS 4.9.

After researching other codes it was determined that two or more risers are considered stairs and would need to comply accordingly.

Therefore, our position is to only apply TAS 4.1.3(4) at those instances of two or more risers.

Applicable to 1994 TAS Only