

1994 Texas Accessibility Standards  
*Technical Memorandum*

---

**Texas Department of Licensing and Regulation  
Architectural Barriers**

Issue Date: July 2, 1999

TM 99-15

---

**Curb Ramps – Surface  
4.7.4(1)**

**Application  
4.7.1**

TAS 4.7.4(2) requires curb ramps to have a light reflective value and surface texture that significantly contrasts with that of adjoining pedestrian routes.

The only surface textures TDLR is currently aware of that meet the intent of this standard are truncated domes meeting the technical specifications of TAS 4.29.2.

Other textures such as grooves 1/4" deep and 3/4" wide 2" apart and arranged so that water will not accumulate, may be acceptable provided the surfaces are detectable underfoot. Other designs for surfaces that are detectable underfoot may be submitted for consideration.