

## Exhibit 8

### SIZE OF BOTTOM BLOWOFF PIPING, VALVES, AND COCKS

Minimum Required Safety Valve Capacity lb. (kg) of Steam/Hr.	Blowoff Piping Valves, and Cocks Size, min. in. (mm)
(Note)	
Up to 500 (226)	$\frac{3}{4}$ (20)
501 to 1,250 (227 to 567)	1 (25)
1,251 to 2,500 (568 to 1184)	1 $\frac{1}{4}$ (32)
2,501 to 6,000 (1185 to 2721)	1 $\frac{1}{2}$ (40)
6,001 (2722) and Larger	2 (50)

Note: To determine the discharge capacity of safety relief valves in terms of Btu, the relieving capacity in lbs. of steam/hr. is multiplied by 1,000.