



## TEXAS DEPARTMENT OF LICENSING AND REGULATION

Compliance Division/Elevator Program

P. O. Box 12157 • Austin, Texas 78711 • (512) 539-5725 • (800) 803-9202

Fax: (512) 539-5729 • Email: [CS.Elevators.Escalators@tdlr.texas.gov](mailto:CS.Elevators.Escalators@tdlr.texas.gov) • Web site: [www.tdlr.texas.gov](http://www.tdlr.texas.gov)

October 14, 2015

Barry Stewart  
Regional President, Central Region  
ThyssenKrupp Elevator Company  
2801 Network Blvd., Suite 700  
Frisco, TX. 75034

**Re: New Technology Variance for Variable Speed Escalators and Moving Walks  
NTV 15-05**

Dear Mr. Stewart,

The Texas Department of Licensing and Regulation (the Department) is pleased to inform you that your New Technology Variance request to install *ThyssenKrupp Elevator Variable Speed Escalators and Moving Walks* is approved.

The approval is based upon the New Technology Variance Application and supporting documentation submitted to the Department on August 21, 2015. Any deviations (i.e. in manufacturing, installation, or advances in technology) from the original NTV application and supporting documentation nullifies this approval and can only be considered upon submittal of another New Technology Variance.

Approval of the New Technology Variance is based on the *ASME A17.1 – 2007* edition of the *Safety Code for Elevators and Escalators*, which is the currently adopted standard in Texas. This variance approval is granted allowing exceptions to the new installation and alteration requirements of:

- **Section 6.1.4.1 Rated Speed** for escalators
- **Section 6.2.4 Rated Speed** for moving walks

The New Technology Variance approval is also subject to the following terms and conditions:

1. Each escalator installation or alteration using this technology must comply with **Sections 6.1.4.1.1** and **6.1.4.1.2** of the *ASME A17.1 – 2013*.
2. Each moving walk installation or alteration using this technology must comply with **Sections 6.2.4.1.1** and **6.2.4.1.2** of the *ASME A17.1 – 2013*.
3. A copy of the variance, variance approval letter, and plan review (including the actual date of installation or alteration) must be maintained in the Maintenance Control Program for the life of the equipment or until such time as the product meets all of the adopted standards in Texas.

4. The applicant must ensure a written report of all incidents and accidents on any equipment that has incorporated this new technology is provided to TDLR within 24 hours of occurrence.

This approval shall apply to all new installations and alterations anywhere in the State of Texas, except the City of Houston. Consideration for approval must be requested directly from the City of Houston.

This approval by the Department shall remain in effect unless revoked. A copy of this approval will be made available to all registered inspectors and elevator personnel. Inspectors shall be informed that the requirements covered by the above variance are not to be cited on any inspection reports. No waivers or delays will be required.


If you agree with the conditions and terms contained in this approval letter, please so indicate by signing and dating a copy of this letter and returning it to the Department. If we can be of any further assistance in this matter, please do not hesitate to contact us.

Sincerely,



Jim Murnan  
Chief Elevator Inspector  
Business and Building Section  
Compliance Division - TDLR

Accepted by the Applicant:



Signature

11/9/15

Date

Barry Stewart - President, Central Region

Printed Name and Title